

**CDBG STREETLIGHT CONDUIT PROJECT  
Merriam, Kansas**

**ADDENDUM NO. 1  
April 5, 2024**

**TO ALL PROSPECTIVE BIDDERS:**

This addendum includes the following clarifications:

- The streetlight conduit materials provided by the City of Merriam to the contractor for directional bore consists of 2-inch HDPE conduit.

There are no other clarifications or changes to the bid documents.

The undersigned hereby acknowledges receipt of this addendum, which by this reference is hereby incorporated in and becomes a part of the Contract Documents for the above-referenced project.

**PLEASE ATTACH THIS ADDENDUM TO YOUR BID.**

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Title

\_\_\_\_\_  
Address

SEAL

**END OF ADDENDUM NO. 1**